BACKFILL TRENCH 6" LIFTS Bd WITH APPROVED SELECT OR 12" 12" GRANULAR MATERIAL COMPACTED Вс TO 90% STANDARD PROCTER DENSITY VARIES Вс MIDPOINT A OF PIPE GRANULAR MATERIAL-SEC 2.1.8.B FINE CRUSHED ROCK-SEC 2.1.8.A COMPACTED TO 95% OF STANDARD PROCTOR DENSITY Bd ⅓

NOTES

- 1. Bc=OUTSIDE DIAMETER OF PIPE
- 2. Bd=TRENCH WIDTH
- 3. CONTRACTOR SHALL USE TEMPLATE TO SECURE REASONABLY ACCURATE SHAPING OF THE FOUNDATION MATERIAL

↑ NON-LOAD BEARING EMBEDMENT DETAIL NOT TO SCALE

Wichita Falls
TEXAS

3030-NonLoadEmbed.dwg
ACAD DRAWING NAME

	DEC 03					3030-00			
ı	DATE DRAWN					STANDARD DRAWING NO.			
ı	3	11/07	CHANGED NOTE MOVED FILL LEVEL						JCC
	A	07/05							DJB
4	Λ	03/05	COMPLETE REVISION						DJB
ı	NO.	NO. DATE DESCRIPTION							BY
	R	Е	٧	ı	S	ı	0	N	s ′

CITY OF WICHITA FALLS, TX

NON-LOAD BEARING
EMBEDMENT DETAIL

APPROVED

CITY ENGINEER P.E.

NOV 2007 DATE

governed by the City of Wichita Falls Engineering Department. No warranty of any kind is made for any purpose whatsoever. The City of Wichita Falls assumes no responsibility for the to other formats for incorrect results or damages resulting from its use. nis standard is g f Vichita Falls f this standard t DISCLAIMER: The use of : by the City conversion o